

Report Inspeksi Apar Bulan Januari 2026

PCI 84

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2026-01-09	FE023 84 ROASTER AREA 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,5kg	
2026-01-09	FE061 84 ROASTER AREA CONTROL ROOM 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,4kg	
2026-01-09	FE060 84 ROASTER AREA CONTROL ROOM 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,4kg	
2026-01-09	FE063 84 ROASTER AREA CONTROL ROOM LT 2 B	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,2kg	
2026-01-09	FE062 84 ROASTER AREA CONTROL ROOM LT 2 A	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,4kg	
2026-01-09	FE0058 84 ROASTER AREA 6	Liquid gas	ABC	100kg	AF11	15bar	Ya	Ya	Ya	2028-11-15	>100kg	
2026-01-09	FE057 84 ROASTER AREA 5	Liquid gas	ABC	100kg	AF11	15bar	Ya	Ya	Ya	2028-11-15	>100kg	
2026-01-09	FE059 84 ROASTER AREA 7	Liquid gas	ABC	100kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	>100kg	
2026-01-09	FE025 84 ROASTER AREA 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya		8,3kg	Tidak ada label kadaluarsa
2026-01-08	FE016 84 SANITISED ROOM	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,5kg	
2026-01-08	FE020 84 CONTROL ROOM PULVISER 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,9kg	
2026-01-08	FE029 84 CONTROL ROOM PULVISER 2	Liquid gas	ABC	3kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	4,5kg	
2026-01-08	FE021 84 PULVERISER AREA	Liquid gas	ABC	9kg	AF11	14bar	Ya	Ya	Ya	2026-11-23	12,5kg	
2026-01-08	FE077 84 ACM CONTROL ROOM 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2026-01-08	FE054 84 ACM CONTROL ROOM 1	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	13kg	
2026-01-08	FE022 84 STABILIZER/ACM POWDER LV. 10.400	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2026-01-08	FE000 84 ACM POWDER 6	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,3kg	
2026-01-08	FE079 84 ACM POWDER 5	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,4kg	
2026-01-08	FE081 84 ACM POWDER 7	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,7kg	
2026-01-08	FE071 84 ACM POWDER 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,6kg	
2026-01-08	FE084 84 STABILIZER / ACM POWDER LV. 14.500	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2026-01-08	FE083 84 STABILIZER / ACM POWDER LV. 10.000 A	Liquid gas	ABC	6kg	AF11	10bar	Ya	Ya	Ya	2026-06-17	8,2kg	Tabung sudah under pressure
2026-01-08	FE087 84 STABILIZER / ACM POWDER LV. 7.000	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,1kg	
2026-01-08	FE086 84 ACM POWDER 9	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8kg	
2026-01-08	FE076 84 ACM POWDER 4	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	8,3kg	
2026-01-08	FE075 84 ACM POWDER 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,5kg	
2026-01-08	FE078 84 STABILIZER / ACM POWDER LV. 6.500	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya		8,2kg	Tidak ada label kadaluarsa
2026-01-08	FE055 84 SAMPLING ROOM	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,6kg	
2026-01-08	FE082 84 ACM POWDER 8	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,5kg	

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2026-01-08	FE074 84 ACM POUNDER 2	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	12,1kg	
2026-01-07	FE012 84 PANEL ROOM LT 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2026-11-23	8,3kg	
2026-01-07	FE011 84 PRESS AREA 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-03-18	8,2kg	
2026-01-07	FE010 84 PRESS AREA 1	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2030-02-28	8,2kg	
2026-01-07	FE019 84 TEMPERING ROOM 1	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2026-11-23	7,2kg	
2026-01-07	FE035 84 TEMPERING ROOM 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	7,3kg	
2026-01-06	FE038 84 BLOWER LT 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,4kg	
2026-01-06	FE037 84 BLOWER LT 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,1kg	
2026-01-06	FE036 84 BLOWER	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2026-01-06	FE090 84 KORIDOR LAB LT 4	Liquid gas	ABC	3kg	AF11	15bar	Ya	Ya	Ya	2027-03-14	4,8kg	
2026-01-06	FE049 84 MEDIUM PREPARATION ROOM	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya		8,3kg	Tidak ada label kadaluarsa
2026-01-06	FE050 84 ISOLATION ROOM	Liquid gas	ABC	3kg	AF11	15bar	Ya	Ya	Ya	2027-03-14	4,7kg	
2026-01-06	FE051 84 PREPARATION ROOM	Liquid gas	ABC	3kg	AF11	15bar	Ya	Ya	Ya	2028-02-08	4,7kg	
2026-01-06	FE048 84 INSTRUMENT ROOM	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-02-08	8,5kg	
2026-01-06	FE045 84 ADM OFFICE	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,2kg	
2026-01-06	FE047 84 MEETING ROOM	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-06-17	8,5kg	
2026-01-06	FE031 84 KORIDOR OFFICE LT 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,5kg	
2026-01-06	FE030 84 TRAINING ROOM	Liquid gas	ABC	6kg	AF11		Ya	Ya	Ya	2028-02-08	8,2kg	
2026-01-06	FE094 84 ACCOUNTING ROOM	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,3kg	
2026-01-06	FEIC 84 MEZZANINE OFFICE LT 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,5kg	
2026-01-06	FE095 84 OFFICE R MALABAR	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2026-01-06	FE028 84 KORIDOR OFFICE LT 2 B	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	8,7kg	
2026-01-06	FE027 84 KORIDOR OFFICE LT 2 A	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,7kg	
2026-01-06	FEIC 84 OFFICE LT 2 DEPAN R. SITE MGR	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2026-01-06	FE043 84 WTP 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-09-25	7,1kg	
2026-01-06	FE044 84 WTP 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	8,6kg	
2026-01-06	FE042 84 ISO TANK	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,4kg	
2026-01-06	FE040 84 LOADING / UNLOADING	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,4kg	
2026-01-06	FE002 84 MDP ROOM 2	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	12,3kg	
2026-01-06	FE001 84 MDP ROOM 1	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	12,5kg	
2026-01-06	FE009 84 TECHNICAL W/H	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,4kg	
2026-01-05	FE046 84 WORKSHOP	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-06-17	8,8kg	
2026-01-05	FE097 84 WORKSHOP 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,5kg	
2026-01-05	FE009 84 CERES	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya		8,2kg	Label kadaluarsa sudah pudar
2026-01-05	FE072 84 TRAF0 ROOM 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,5kg	
2026-01-05	FE073 84 TRAF0 ROOM 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,5kg	
2026-01-05	FE039 84 TRAF0 ROOM 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2026-01-05	FE013 84 NIBS DUMPING AREA	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-09-25	7,3kg	
2026-01-05	FE003 84 UTILITY/CHILLER AREA 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,3kg	
2026-01-05	FE034 84 UTILITY / CHILLER AREA 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,5kg	
2026-01-05	FE033 84 UTILITY / CHILLER AREA 2	Liquid gas	ABC	6kg	AF11	10bar	Ya	Ya	Ya	2029-09-10	7,9kg	Tabung sudah under pressure
2026-01-05	FE053 84 DEODORISER LT 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	8,9kg	
2026-01-05	FE052 84 DEODORISER LT 2	Liquid gas	ABC	3,5kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	5,4kg	
2026-01-05	FE017 84 KORIDOR OFFICE PRODUCTION 1	Liquid gas	ABC	3,5kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	5,5kg	
2026-01-05	FE018 84 KORIDOR OFFICE PRODUCTION 2	Liquid gas	ABC	3,5kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	5,5kg	
2026-01-05	FE009 84 CERES	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-09-25	7,1kg	
2026-01-05	FE005 84 KORIDOR 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-03-18	8,5kg	

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2026-01-05	FE006 84 KORIDOR 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	8,3kg	
2026-01-05	FE006 84 KORIDOR 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	8,3kg	
2026-01-05	FE007 84 KORIDOR 4	Liquid gas	ABC	7kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	11,7kg	
2026-01-05	FE006 84 KORIDOR 3	Liquid gas	ABC	7kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	11,7kg	
2026-01-05	FE008 84 KORIDOR 5	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	9,2kg	
2026-01-05	FE088 84 POS SECURITY 3	Liquid gas	ABC	6kg	AF11	12bar	Ya	Ya	Ya	2029-09-10	8,3kg	
2026-01-05	FE041 84 POS SECURITY 2	Liquid gas	ABC	6kg	AF11	18bar	Ya	Ya	Ya	2029-01-11	8,4kg	
2026-01-05	FE032 84 POS SECURITY 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	

MENGGER

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2026-01-16	FEM053 MG R. SAMPIING KIRI FINISH GOOD	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-03-18	8,3kg	
2026-01-15	FEM039 MG R. GUDANG BIJI BEAN W/H 13	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,3kg	
2026-01-15	FEM027 MG R. GUDANG BIJI BEAN W/H 1	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,2kg	
2026-01-15	FEM037 MG R. GUDANG BIJI BEAN W/H 11	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,4	
2026-01-15	FEM029 MG R. GUDANG BIJI BEAN W/H 3	Liquid gas	ABC	6 kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,3kg	
2026-01-15	FEM028 MG R. GUDANG BIJI BEAN W/H 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,4kg	
2026-01-15	FEM030 MG R. GUDANG BIJI BEAN W/H 4	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,5kg	
2026-01-15	FEM031 MG R. GUDANG BIJI BEAN W/H 5	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,3kg	
2026-01-15	FEM032 MG R. GUDANG BIJI BEAN W/H 6	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,3kg	
2026-01-15	FEM033 MG R. GUDANG BIJI BEAN W/H 7	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,7kg	
2026-01-15	FEM034 MG R. GUDANG BIJI BEAN W/H 8	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-03-18	9,9kg	
2026-01-15	FEM035 MG R. GUDANG BIJI BEAN W/H 9	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2030-02-03	8,3kg	
2026-01-15	FEM037 MG R. GUDANG BIJI BEAN W/H 11	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-05-21	8,2kg	
2026-01-15	FEM038 MG R. GUDANG BIJI BEAN W/H 12	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-03-18	9,3	
2026-01-15	FEM041 MG R. GUDANG BIJI BEAN W/H 15	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-05-18	8,3kg	
2026-01-15	FEM040 MG R. GUDANG BIJI BEAN W/H 14	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-03-18	8,3kg	
2026-01-15	FEM048 MG R. WASTE STORAGE 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,3kg	
2026-01-15	FEM013 MG R. CNG	Liquid gas	Co2	9kg	AF11	-	Ya	Ya	Ya		-	
2026-01-15	FEM003 MG SUGAR WH 3	Liquid gas	ABC	9kg	AF11	15	Ya	Ya	Ya	2026-11-23	12,2kg	
2026-01-15	FEM002 MG SUGAR WH 2	Liquid gas	ABC	9kg	AF11	15	Ya	Ya	Ya	2026-11-23	12,9	
2026-01-15	FEM001 MG SUGAR WH 1	Liquid gas	ABC	9kg	AF11	15	Ya	Ya	Ya	2026-11-23	12,6	
2026-01-15	FEM012 MG R. FINISH GOOD 8	Liquid gas	ABC	3,5kg	AF11	15	Ya	Ya	Ya	2028-06-02	5,1kg	

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2026-01-15	FEM011 MG R. FINISH GOOD 7	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,7kg	
2026-01-15	FEM010 MG R. FINISH GOOD 6	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	,8,2kg	
2026-01-15	FEM009 MG R. FINISH GOOD 5	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,2 kg	
2026-01-15	FEM008 MG R. FINISH GOOD 4	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,3 kg	
2026-01-15	FEM007 MG R. FINISH GOOD 3	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,2 kg	
2026-01-15	FEM006 MG R. FINISH GOOD 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,4kg	
2026-01-15	FEM005 MG R. FINISH GOOD 1	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,4kg	
2026-01-15	FEM004 MG R. OFFICE WH	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,6	
2026-01-15	FEM045 MG R. BC STUDIO 2	Liquid gas	ABC	3kg	AF11	15	Ya	Ya	Ya	2026-11-23	5,0kg	
2026-01-15	FEM044 MG R. BC STUDIO 1	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-03-18	5,4kg	
2026-01-13	FEM014 MG R. KANTIN	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2026-06-17	10kg	
2026-01-13	FEM016 MG R. WINNOWER ROOM 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,4kg	
2026-01-13	FEM043 MG R. WTP 1	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,4kg	
2026-01-13	FEM046 MG R. WTP 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,4kg	
2026-01-13	FEM050 MG R. WORKSHOP 1	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,3kg	
2026-01-13	FEM051 MG R. WORKSHOP 2	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,2kg	
2026-01-13	FEM023 MG R. WINNOWER ROOM 9	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	9kg	
2026-01-13	FEM022 MG R. WINNOWER ROOM 8	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,5kg	
2026-01-13	FEM019 MG R. WINNOWER ROOM 5	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-05-21	8,2kg	
2026-01-13	FEM020 MG R. WINNOWER ROOM 6	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,3kg	
2026-01-13	FEM020 MG R. WINNOWER ROOM 6	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,3kg	
2026-01-13	FEM021 MG R. WINNOWER ROOM 7	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-09-10	8,1kg	
2026-01-13	FEM026 MG R. PANEL	Liquid gas	ABC	3,5kg	AF11	15	Ya	Ya	Ya	2029-03-18	5,7kg	
2026-01-13	FEM018 MG R. WINNOWER ROOM 4	Liquid gas	ABC	100kg	AF11	15	Ya	Ya	Ya	2025-02-17	>100	Tabung sudah expired
2026-01-13	FEM017 MG R. WINNOWER ROOM 3	Liquid gas	ABC	100kg	AF11	15	Ya	Ya	Ya	2024-10-18	>100	Tabung sudah expired
2026-01-13	FEM015 MG R. WINNOWER ROOM 1	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2028-06-02	8,4kg	
2026-01-13	FEM054 MG R. WINNOWER ROOM 12	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-03-18	8,3 kg	

BINTANG AGUNG

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2026-01-19	FEBA037 OFFICE BINTANG AGUNG 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,2kg	
2026-01-19	FEBA038 OFFICE BINTANG AGUNG 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,4kg	
2026-01-19	FEBA027 GUDANG 1 BA 9	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,4kg	
2026-01-19	FEBA028 GUDANG 1 BA 10	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-12-18	8,2kg	

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2026-01-19	FEBA029 GUDANG 1 BA 11	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,2kg	
2026-01-19	FEBA030 GUDANG 1 BA 12	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2026-01-19	FEBA031 GUDANG 1 BA 13	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2026-01-19	FEBA032 GUDANG 1 BA 14	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,4kg	
2026-01-19	FEBA033 GUDANG 1 BA 15	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,8kg	
2026-01-19	FEBA008 GUDANG 1 BA 8	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,5kg	
2026-01-19	FEBA005 GUDANG 1 BA 5	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,2kg	
2026-01-19	FEBA006 GUDANG 1 BA 6	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,2kg	
2026-01-19	FEBA007 GUDANG 1 BA 7	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2026-01-19	FEBA004 GUDANG 1 BA 4	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,8kg	
2026-01-19	FEBA003 GUDANG 1 BA 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-12-18	8,4kg	
2026-01-19	FEBA002 GUDANG 1 BA 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,2kg	
2026-01-19	FEBA001 GUDANG 1 BA 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,1kg	
2026-01-19	FEBA035 GUDANG 1 BA 17	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8kg	
2026-01-19	FEBA034 GUDANG 1 BA 16	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,4kg	
2026-01-19	FEBA023 GUDANG 2 BA 15	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	12,8kg	
2026-01-19	FEBA022 GUDANG 2 BA 14	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,4kg	
2026-01-19	FEBA021 GUDANG 2 BA 13	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,6kg	
2026-01-19	FEBA020 GUDANG 2 BA 12	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,8kg	
2026-01-19	FEBA019 GUDANG 2 BA 11	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-12-18	8kg	
2026-01-19	FEBA018 GUDANG 2 BA 10	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,3kg	
2026-01-19	FEBA017 GUDANG 2 BA 9	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,2kg	
2026-01-19	FEBA016 GUDANG 2 BA 8	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2026-01-19	FEBA015 GUDANG 2 BA 7	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2029-05-21	8,4kg	
2026-01-19	FEBA014 GUDANG 2 BA 6	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,1kg	
2026-01-19	FEBA013 GUDANG 2 BA 5	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2026-01-19	FEBA012 GUDANG 2 BA 4	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,1kg	
2026-01-19	FEBA011 GUDANG 2 BA 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	7,8kg	
2026-01-19	FEBA010 GUDANG 2 BA 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,1kg	
2026-01-19	FEBA036 OFFICE BINTANG AGUNG	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,6kg	
2026-01-19	FEBA024 GUDANG 2 BA 16	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,7kg	
2026-01-19	FEBA009 GUDANG 2 BA 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,8kg	
2026-01-19	FEBA025 GUDANG 2 BA 17	Liquid gas	ABC	3,5kg	AF11	15bar	Ya	Ya	Ya	2030-09-20	5kg	
2026-01-19	FEBA026 GUDANG 2 BA 18	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	

