

# Report Inspeksi Apar Bulan Juli 2025

## PCI 84

Tanggal-Inspeksi	Kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-08	FE072 04 TRAF0 ROOM 1	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,5	
2025-07-08	FE073 04 TRAF0 ROOM 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2025-05-04	8,4	Sudah expired
2025-07-08	FE039 04 TRAF0 ROOM 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2025-05-04	8,5	Sudah expired
2025-07-08	FE058 04 ROASTER AREA 6	Liquid gas	ABC	100	AF11	15 bar	Ya	Ya	Ya	2028-11-15	>100	
2025-07-08	FE057 04 ROASTER AREA 5	Liquid gas	ABC	100kg	AF11	18 bar	Ya	Ya	Ya	2028-11-15	>100	
2025-07-08	FE059 04 ROASTER AREA 7	Liquid gas	ABC	100kg	AF11	17 bar	Ya	Ya	Ya	2029-05-21	>100	
2025-07-08	FE024 04 ROASTER AREA 2	Liquid gas	ABC	6kg	AF11	9bar	Ya	Ya	Ya	2026-01-11	5,6	Pressure turun
2025-07-08	FE063 04 ROASTER AREA CONTROL ROOM LT 2 B	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,3	
2025-07-08	FE061 04 ROASTER AREA CONTROL ROOM 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,2	
2025-07-08	FE062 04 ROASTER AREA CONTROL ROOM LT 2 A	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,5	
2025-07-08	FE060 04 ROASTER AREA CONTROL ROOM 1	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,4	
2025-07-08	FE061 04 ROASTER AREA CONTROL ROOM 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,3	
2025-07-08	FE023 04 ROASTER AREA 1	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,5	
2025-07-08	FE025 04 ROASTER AREA 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya		8,2	
2025-07-08	FE018 04 KORIDOR OFFICE PRODUCTION 2	Liquid gas	ABC	3,5 kg	AF11	17 bar	Ya	Ya	Ya	2026-11-23	5,5	
2025-07-08	FE017 04 KORIDOR OFFICE PRODUCTION 1	Liquid gas	ABC	3,5 kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	5,5 kg	
2025-07-08	FE016 04 SANITISED ROOM	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,5 kg	
2025-07-08	FE021 04 PULVERISER AREA	Liquid gas	ABC	9kg	AF11	11 bar	Ya	Ya	Ya	2026-11-23	12,5	
2025-07-08	FE020 04 CONTROL ROOM PULVISER 2	Liquid gas	ABC	3kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	4,5 kg	
2025-07-08	FE020 04 CONTROL ROOM PULVISER 1	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,9 kg	
2025-07-08	FE012 04 PANEL ROOM LT 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,3 kg	
2025-07-08	FE011 04 PRESS AREA 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-03-18	8,2	
2025-07-08	FE010 04 PRESS AREA 1	Liquid gas	ABC	6kg	AF11	18 bar	Ya	Ya	Ya	2030-02-28	8,2 kg	
2025-07-05	FE081 04 ACM POWDER 7	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,7kg	
2025-07-05	FE081 04 ACM POWDER 7	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,7kg	
2025-07-05	FE071 04 ACM POWDER 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,6kg	
2025-07-05	FE085 04 STABILIZER / ACM POWDER LV. 10.000 B	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8kg	
2025-07-05	FE087 04 STABILIZER / ACM POWDER LV. 7.000	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,1kg	
2025-07-05	FE083 04 STABILIZER / ACM POWDER LV. 10.000 A	Liquid gas	ABC	6kg	AF11	15bar	Ya	Tidak	Ya	2026-06-17	8,2kg	-pin apar tidak ada Papan sign apar patah.. Perlu di ganti
2025-07-05	FE085 04 STABILIZER / ACM POWDER LV. 10.000 B	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2028-02-28	12,4kg	

Tanggal-Inspeksi	Kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-05	FE022 84 STABILIZER/ACM POWDER LV. 10.400	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2025-07-05	FE077 84 ACM CONTROL ROOM 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2025-07-05	FE054 84 ACM CONTROL ROOM 1	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	13kg	
2025-07-05	FE078 84 STABILIZER / ACM POWDER LV. 6.500	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya		8,2	Non tagging expired
2025-07-05	FE055 84 SAMPLING ROOM	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,6kg	
2025-07-05	FE055 84 SAMPLING ROOM	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,6kg	
2025-07-05	FE082 84 ACM POWDER 8	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,5kg	
2025-07-05	FE075 84 ACM POWDER 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2030-02-28	8,5kg	
2025-07-05	FE076 84 ACM POWDER 4	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	8,3kg	
2025-07-05	FE079 84 ACM POWDER 5	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,4kg	
2025-07-05	FE080 84 ACM POWDER 6	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,3kg	
2025-07-05	FE074 84 ACM POWDER 2	Liquid gas	ABC	9kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	12,1	
2025-07-05	FE035 84 TEMPERING ROOM 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,6kg	
2025-07-05	FE035 84 TEMPERING ROOM 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,6kg	
2025-07-05	FE035 84 TEMPERING ROOM 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,6kg	
2025-07-05	FE019 84 TEMPERING ROOM 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	8,6kg	
2025-07-01	FE001 84 MDP ROOM 1	Liquid gas	ABC	9kg	AF11	16 bar	Ya	Ya	Ya	2026-11-23	12,5	
2025-07-01	FE002 84 MDP ROOM 2	Liquid gas	ABC	9kg	AF11	15 bar	Ya	Ya	Ya	2026-11-20	12,3	
2025-07-01	FE089 84 TECHNICAL W/H	Liquid gas	ABC	6kg	AF11	18 bar	Ya	Ya	Ya	2030-02-28	8,4	
2025-07-01	FE040 84 LOADING / UNLOADING	Liquid gas	ABC	6kg	AF11	7bar	Ya	Ya	Ya	2026-11-23	8,5	Pressure turun
2025-07-01	FE044 84 WWTP 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-01-11	8,6	Tidak ada segel
2025-07-01	FE043 84 WWTP 1	Liquid gas	ABC	6kg	AF11	0bar	Ya	Ya	Ya	2029-09-10	7,8	Prepressure turun habis
2025-07-01	FE042 84 ISO TANK	Liquid gas	ABC	6 kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,4	
2025-07-01	FE003 84 UTILITY/CHILLER AREA 1	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,3	
2025-07-01	FE034 84 UTILITY / CHILLER AREA 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,4	
2025-07-01	FE053 84 DEODORISER LT 3	Liquid gas	ABC	6kg	AF11	16 bar	Ya	Ya	Ya	2026-01-11	8,9 kg	
2025-07-01	FE052 84 DEODORISER LT 2	Liquid gas	ABC	3,5 kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	5,4 kg	
2025-07-01	FE004 84 KORIDOR 1	Liquid gas	ABC	6kg	AF11	17bar	Ya	Ya	Ya	2029-03-18	8,6 kg	
2025-07-01	FE005 84 KORIDOR 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-07-18	8,6 kg	
2025-07-01	FE006 84 KORIDOR 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-01-11	8,3 kg	
2025-07-01	FE007 84 KORIDOR 4	Liquid gas	ABC	7 kg	AF11	15 bar	Ya	Ya	Ya	2026-01-11	11,7 kg	
2025-07-01	FE008 84 KORIDOR 5	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-01-11	9,2 kg	
2025-07-01	FE038 84 BLOWER LT 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2024-11-16	8,4	Sudah expired
2025-07-01	FE037 84 BLOWER LT 2	Liquid gas	ABC	6kg	AF11	17 bar	Ya	Ya	Ya	2024-11-16	8,5	Sudah expired
2025-07-01	FE036 84 BLOWER	Liquid gas	ABC	6kg	AF11	17bar	Ya	Ya	Ya	2024-11-16	7,9 kg	Sudah expired
2025-07-01	FE026 84 CANTEEN LT 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,5	
2025-07-01	FE030 84 TRAINING ROOM	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-02-08	8,2 kg	
2025-07-01	FE049 84 MEDIUM PREPARATION ROOM	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya		8,3	
2025-07-01	FE051 84 PREPARATION ROOM	Liquid gas	ABC	3kg	AF11	15 bar	Ya	Ya	Ya	2028-02-09	4,7 kg	
2025-07-01	FE048 84 INSTRUMENT ROOM	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-02-08	8,5 kg	
2025-07-01	FE090 84 KORIDOR LAB LT 4	Liquid gas	ABC	3kg	AF11	15 bar	Ya	Ya	Ya	2027-03-14	4,8 kg	
2025-07-01	FE045 84 ADM OFFICE	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,2 kg	
2025-07-01	FE047 84 MEETING ROOM	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-06-17	8,5 kg	
2025-07-01	FE031 84 KORIDOR OFFICE LT 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,5	
2025-07-01	FE1C 84 MEZZANINE OFFICE LT 2	Liquid gas	ABC	6 kg	AF11	15 bar	Ya	Ya	Ya	2030-02-28	8,5 kg	
2025-07-01	FE094 84 ACCOUNTING ROOM	Liquid gas	ABC	6 kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,3 kg	

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-01	FE028 84 KORIDOR OFFICE LT 2 B	Liquid gas	ABC	6 kg	AF11	15 bar	Ya	Ya	Ya	2026-01-11	8,7	
2025-07-01	FE1C 84 OFFICE LT 2 DEPAN R. SITE MGR	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2030-02-28	8,3kg	
2025-07-01	FE027 84 KORIDOR OFFICE LT 2 A	Liquid gas	ABC	3kg	AF11	0 bar	Ya	Ya	Ya	2027-03-14	4,8	Pressure turun habis
2025-07-01	FE013 84 NIBS DUMPING AREA	Liquid gas	ABC	3kg	AF11	10 bar	Ya	Ya	Ya	2028-11-15	4,6	Pressure turun
2025-07-01	FE009 84 CERES	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-11-15	8,3 kg	
2025-07-01	FE046 84 WORKSHOP	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-17	8,8 kg	
2025-07-01	FE088 84 POS SECURITY 3	Liquid gas	ABC	6 kg	AF11	12bar	Ya	Ya	Ya	2029-09-10	8,3 kg	
2025-07-01	FE041 84 POS SECURITY 2	Liquid gas	ABC	6kg	AF11	18 bar	Ya	Ya	Ya	2028-01-11	8,4 kg	
2025-07-01	FE032 84 POS SECURITY 1	Liquid gas	ABC	6 kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,3 kg	

# MENGGER

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-10	FEM050 MG R. WORKSHOP 1	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2029-09-10	8,3kg	
2025-07-10	FEM051 MG R. WORKSHOP 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,2kg	
2025-07-10	FEM046 MG R. WWT 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,4kg	
2025-07-10	FEM043 MG R. WWT 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2025-07-10	9,2kg	
2025-07-10	FEM028 MG R. GUDANG BIJI BEAN W/H 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,6kg	
2025-07-10	FEM030 MG R. GUDANG BIJI BEAN W/H 4	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2029-09-10	8,5kg	
2025-07-10	FEM029 MG R. GUDANG BIJI BEAN W/H 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,3kg	
2025-07-10	FEM027 MG R. GUDANG BIJI BEAN W/H 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,2kg	
2025-07-10	FEM039 MG R. GUDANG BIJI BEAN W/H 13	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2025-07-10	FEM037 MG R. GUDANG BIJI BEAN W/H 11	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,2kg	
2025-07-10	FEM036 MG R. GUDANG BIJI BEAN W/H 10	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,4kg	
2025-07-10	FEM031 MG R. GUDANG BIJI BEAN W/H 5	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,4kg	
2025-07-10	FEM032 MG R. GUDANG BIJI BEAN W/H 6	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2025-07-10	FEM032 MG R. GUDANG BIJI BEAN W/H 6	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2025-07-10	FEM033 MG R. GUDANG BIJI BEAN W/H 7	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,7kg	
2025-07-10	FEM034 MG R. GUDANG BIJI BEAN W/H 8	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-03-18	9,9kg	
2025-07-10	FEM035 MG R. GUDANG BIJI BEAN W/H 9	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-03	8,3kg	
2025-07-10	FEM041 MG R. GUDANG BIJI BEAN W/H 15	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2029-03-21	8,3kg	
2025-07-10	FEM040 MG R. GUDANG BIJI BEAN W/H 14	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-03-18	8,3kg	
2025-07-10	FEM026 MG R. PANEL	Liquid gas	ABC	3,5kg	AF11	15 bar	Ya	Ya	Ya	2028-03-18	5,7kg	

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-10	FEM023 MG R. WINNOWER ROOM 9	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,9kg	
2025-07-10	FEM021 MG R. WINNOWER ROOM 7	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,1kg	
2025-07-10	FEM020 MG R. WINNOWER ROOM 6	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,3kg	
2025-07-10	FEM022 MG R. WINNOWER ROOM 8	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2029-09-10	8,5kg	
2025-07-10	FEM019 MG R. WINNOWER ROOM 5	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,2kg	
2025-07-10	FEM018 MG R. WINNOWER ROOM 4	Liquid gas	ABC	100kg	AF11	18bar	Ya	Ya	Ya	2024-10-18	-	Tabung sudah expired, harus di refill
2025-07-10	FEM017 MG R. WINNOWER ROOM 3	Liquid gas	ABC	100kg	AF11	15 bar	Ya	Ya	Ya	2025-02-11	-	Tabung sudah expired, harus di refill
2025-07-10	FEM015 MG R. WINNOWER ROOM 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,4kg	
2025-07-10	FEM054 MG R. WINNOWER ROOM 12	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-04-18	8,3kg	
2025-07-09	FEM016 MG R. WINNOWER ROOM 2	Liquid gas	ABC	6kg	AF11	10bar	Ya	Ya	Ya	2025-11-18	8,6kg	
2025-07-09	FEM014 MG R. KANTIN	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-06-17	10kg	
2025-07-09	FEM047 MG R. WASTE STORAGE 1	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,4kg	
2025-07-09	FEM048 MG R. WASTE STORAGE 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-09-10	8,4kg	
2025-07-09	FEM013 MG R. CNG	CO2	CO	9kg	AF11	-	Ya	Ya	Ya		28mg	No tagging expired
2025-07-09	FEM003 MG SUGAR WH 3	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	12,9kg	Cantolan bracket patah
2025-07-09	FEM003 MG SUGAR WH 3	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	12,2kg	
2025-07-09	FEM002 MG SUGAR WH 2	Liquid gas	ABC	9kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	12,9kg	
2025-07-09	FEM001 MG SUGAR WH 1	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2026-11-23	12,6kg	
2025-07-09	FEM012 MG R. FINISH GOOD 8	Liquid gas	ABC	3,5kg	AF11	16bar	Ya	Ya	Ya	2028-06-02	5,1kg	
2025-07-09	FEM010 MG R. FINISH GOOD 6	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,2kg	
2025-07-09	FEM009 MG R. FINISH GOOD 5	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2025-07-09	FEM008 MG R. FINISH GOOD 4	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2025-07-09	FEM005 MG R. FINISH GOOD 1	Liquid gas	ABC	6kg	AF11	15bark	Ya	Ya	Ya	2028-06-02	8,4kg	
2025-07-09	FEM006 MG R. FINISH GOOD 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,4kg	
2025-07-09	FEM007 MG R. FINISH GOOD 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,2kg	
2025-07-09	FEM004 MG R. OFFICE WH	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-02-10	8,6kg	
2025-07-09	FEM052 MG R. MAIN PILOT AREA	Liquid gas	ABC	3kg	AF11	15bar	Ya	Ya	Ya	2026-01-11	4,4kg	
2025-07-09	FEM053 MG R. SAMPIING KIRAI FINISH GOOD	Liquid gas	ABC	6kg	AF11	15 ar	Ya	Ya	Ya	2029-03-18	8,3	
2025-07-09	FEM045 MG R. BC STUDIO 2	Liquid gas	ABC	3kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	5kg	
2025-07-09	FEM044 MG R. BC STUDIO 1	Liquid gas	ABC	3,5kg	AF11	15bar	Ya	Ya	Ya	2029-03-18	5,4kg	

# BINTANG AGUNG

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-14	FEBA038 OFFICE BINTANG AGUNG 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2030-02-28	8,4	

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-14	FEB037 OFFICE BINTANG AGUNG 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2030-02-28	8,3	
2025-07-14	FEB023 GUDANG 2 BA 15	Liquid gas	ABC	9kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	12,8	
2025-07-14	FEB022 GUDANG 2 BA 14	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,4	
2025-07-14	FEB021 GUDANG 2 BA 13	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,6	
2025-07-14	FEB029 GUDANG 1 BA 11	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,2	
2025-07-14	FEB028 GUDANG 1 BA 10	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-12-18	8,3	
2025-07-14	FEB027 GUDANG 1 BA 9	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2026-11-23	8,4	
2025-07-14	FEB001 GUDANG 1 BA 1	Liquid gas	ABC	6kg	AF11	15 bat	Ya	Ya	Ya	2029-05-21	8,1	
2025-07-14	FEB035 GUDANG 1 BA 17	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8	
2025-07-14	FEB034 GUDANG 1 BA 16	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,4	
2025-07-14	FEB002 GUDANG 1 BA 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,5	
2025-07-14	FEB003 GUDANG 1 BA 3	Liquid gas	ABC	6kg	AF11	15 bsr	Ya	Ya	Ya	2028-12-18	8,4	
2025-07-14	FEB004 GUDANG 1 BA 4	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,8	
2025-07-14	FEB005 GUDANG 1 BA 5	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,2	
2025-07-14	FEB008 GUDANG 1 BA 8	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,5	
2025-07-14	FEB007 GUDANG 1 BA 7	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,3	
2025-07-14	FEB033 GUDANG 1 BA 15	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,8	
2025-07-14	FEB032 GUDANG 1 BA 14	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,5	
2025-07-14	FEB030 GUDANG 1 BA 12	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,3	
2025-07-14	FEB020 GUDANG 2 BA 12	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,8	
2025-07-14	FEB031 GUDANG 1 BA 13	Liquid gas	ABC	6kg	AF11		Ya	Ya	Ya	2028-06-02	8,3	
2025-07-14	FEB019 GUDANG 2 BA 11	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-12-18	8	
2025-07-14	FEB018 GUDANG 2 BA 10	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,3	
2025-07-14	FEB017 GUDANG 2 BA 9	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,3	
2025-07-14	FEB016 GUDANG 2 BA 8	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,3	
2025-07-14	FEB015 GUDANG 2 BA 7	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,4	
2025-07-14	FEB014 GUDANG 2 BA 6	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-09-10	8,1	
2025-07-14	FEB013 GUDANG 2 BA 5	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2030-02-28	8,3	
2025-07-14	FEB012 GUDANG 2 BA 4	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,1kg	
2025-07-14	FEB011 GUDANG 2 BA 3	Liquid gas	ABC	6kg	AF11	15	Ya	Ya	Ya	2029-05-21	7,8	
2025-07-14	FEB010 GUDANG 2 BA 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	8,8kg	
2025-07-14	FEB038 OFFICE BINTANG AGUNG 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2030-02-28	8,4kg	
2025-07-14	FEB036 OFFICE BINTANG AGUNG	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2030-02-28	8,6	
2025-07-14	FEB009 GUDANG 2 BA 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-05-21	7,9kg	cantolan hampir patah
2025-07-14	FEB026 GUDANG 2 BA 18	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,1	
2025-07-14	FEB025 GUDANG 2 BA 17	Liquid gas	ABC	6kg	AF11	8bar	Ya	Ya	Ya	2029-05-21	8	Pressure turun

# RAMATEX

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-11	FEIC RT FEM 035 POTASIAM ROOM 4	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-02-08	12,8	
2025-07-11	FEIC RT FEM 018 WH 15	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2028-02-08	13,2	cantolan bracket patah
2025-07-11	FEIC RT FEM 033 POTASIAM ROOM 2	Liquid gas	ABC	6kg	AF11	18 bar	Ya	Ya	Ya	2028-06-02	8,3	
2025-07-11	FEIC RT FEM 034 POTASIAM ROOM 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,3	
2025-07-11	FEIC RT FEM 023 WH 20	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-11-15	8,3kg	
2025-07-11	FEIC RT FEM 024 WH 21	Liquid gas	ABC	6kg	AF11	9 bar	Ya	Ya	Ya	2029-11-15	7,7	Pressure turun
2025-07-11	FEIC RT FEM 025 WH 22	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,3	
2025-07-11	FEIC RT FEM 022 WH 19	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-05-21	8,5	
2025-07-11	FEIC RT FEM 026 WH 23	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-02-08	8,7	
2025-07-11	FEIC RT FEM 036 OFFICE	Liquid gas	ABC	6kg	AF11	11 bar	Ya	Ya	Ya	2028-11-15	9,2	
2025-07-11	FEIC RT FEM 027 DEPAN OFFICE 1	Liquid gas	ABC	9kg	AF11		Ya	Ya	Ya	2028-11-15	12,9	
2025-07-11	FEIC RT FEM 038 DEPAN OFFICE 4	Liquid gas	ABC	9kg	AF11	15	Ya	Ya	Ya	2026-06-17	12,9	
2025-07-11	FEIC RT FEM 029 DEPAN OFFICE 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-11-15	8,1	
2025-07-11	FEIC RT FEM 030 DEPAN WH	Liquid gas	ABC	3,5kg	AF11	16bar	Ya	Ya	Ya	2028-11-15	5,3kg	
2025-07-11	FEIC RT FEM 031 Loading Bay	Liquid gas	ABC	3,5	AF11	15 bar	Ya	Ya	Ya	2028-11-15	5,3	
2025-07-11	FEIC RT FEM 015 WH 12	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,4kg	
2025-07-11	FEIC RT FEM 016 WH 13	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2028-11-15	12,2	
2025-07-11	FEIC RT FEM 017 WH 14	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-03-18	8,4kg	
2025-07-11	FEIC RT FEM 013 WH 10	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2025-07-11	FEIC RT FEM 018 WH 15	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2029-03-18	8kg	
2025-07-11	FEIC RT FEM 012 WH 9	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2028-11-15	12,6kg	cantolan bracket patah
2025-07-11	FEIC RT FEM 019 WH 16	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2028-10-15	12,5kg	
2025-07-11	FEIC RT FEM 011 WH 8	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2028-11-15	14,3kg	
2025-07-11	FEIC RT FEM 020 WH 17	Liquid gas	ABC	6kg	AF11	10bar	Ya	Ya	Ya	2028-06-02	8,3kg	pressure tabung turun
2025-07-11	FEIC RT FEM 010 WH 7	Liquid gas	ABC	9kg	AF11	15bar	Ya	Ya	Ya	2028-02-08	14,3kg	
2025-07-11	FEIC RT FEM 009 WH 6	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-02-08	10kg	
2025-07-11	FEIC RT FEM 008 WH 5	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2025-07-11	FEIC RT FEM 007 WH 4	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2028-11-15	8,5kg	
2025-07-11	FEIC RT FEM 006 WH 3	Liquid gas	ABC	63,5kg	AF11	15bar	Ya	Ya	Ya	2025-05-04	5,5kg	
2025-07-11	FEIC RT FEM 005 WH 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-11-15	9kg	
2025-07-11	FEIC RT FEM 032 POTASIAM ROOM 1	Liquid gas	ABC	100kg	AF11	15bar	Ya	Ya	Ya	2023-06-29	-	
2025-07-11	FEIC RT FEM 004 WH 1	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-11-15	8,6kg	
2025-07-11	FEIC RT FEM 037 WAREHOUSE 24	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2028-06-02	8,4kg	
2025-07-11	FEIC RT FEM 014 WH 11	Liquid gas	ABC	4,5kg	AF11	18bar	Ya	Ya	Ya	2023-11-10	7kg	tabung expired
2025-07-11	FEIC RT FEM 001 POS SECURITY 1	Liquid gas	ABC	6kg	AF11	16bar	Ya	Ya	Ya	2028-06-02	8,3kg	
2025-07-11	FEIC RT FEM 002 POS SECURITY 2	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2025-05-04	8,2kg	
2025-07-11	FEIC RT FEM 003 POS SECURITY 3	Liquid gas	ABC	6kg	AF11	15bar	Ya	Ya	Ya	2028-06-02	8,4kg	

# TEGUH JAYA

Tanggal-Inspeksi	kode-area	jenis-media	Fire-Rating	Kapasitas	Kode-Media	Tekanan	Kondisi-Selang-Baik	Pin-Terpasang	Kondisi-Handel-Baik	KadaLuarsa-Media	Berat-Kotor	Keterangan
2025-07-11	FEIC TJ FEBA 006 WH 5	Liquid gas	ABC	6kg	AF11	7bar	Ya	Ya	Ya	2029-03-18	7,9	Pressure turun
2025-07-11	FEIC TJ FEBA 002 WH 1	Liquid gas	ABC	9kg	AF11	15 bar	Ya	Ya	Ya	2025-05-04	12,5	Sudah expired
2025-07-11	FEIC TJ FEBA 001 SECURITY	Liquid gas	ABC	3,5 kg	AF11	15 bar	Ya	Ya	Ya	2028-03-18	5,6	
2025-07-11	FEIC TJ FEBA 003 WH 2	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,2	
2025-07-11	FEIC TJ FEBA 008 WH 7	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,3	
2025-07-11	FEIC TJ FEBA 009 WH 8	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	8,4	
2025-07-11	FEIC TJ FEBA 007 WH 6	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2029-03-18	8,1	
2025-07-11	FEIC TJ FEBA 004 WH 3	Liquid gas	ABC	6kg	AF11	15 bar	Ya	Ya	Ya	2028-06-02	9kg	
2025-07-11	FEIC TJ FEBA 005 WH 4	Liquid gas	ABC	6kg	AF11	8bar	Ya	Ya	Ya	2028-06-02	6,3	Pressure turun
2025-07-11	FEIC TJ FEBA 004 WH 3	Liquid gas	ABC	6kg	AF11	8bar	Ya	Ya	Ya	2028-06-02	8,3	Pressure turun